

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 2230012

Ordering firm: KOPOS KOLÍN a.s.  
Havlíčkova 432, 280 02 Kolín IV, Czech Republic

Manufacturer/Licence holder: KOPOS KOLÍN a.s.  
Havlíčkova 432, 280 02 Kolín IV, Czech Republic

Production site:

Name of product: Electroinstallation plastic boxes in enclosed design and accessories

Trade name:

Type of product: 8130, 8135, 003..., 005.. (see Annex)

Rating: see Annex

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „ESČ Mark” certification scheme is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESC Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 222274-01/01 of: 28.03.2023

A sample of the product was tested and found to be in conformity with:

ČSN EN IEC 60670-1 ed.2:21+A11:21, ČSN EN 60670-1:05+Z1:10+A1:13+Z2:21, ČSN 60670-22:07

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 No. 221041-01 of 12.05.2022
- the Agreement on the use of the ESC Mark No. 222274 concluded between the ordering firm and the Electrotechnical Testing Institute

Other data:

03.04.2023

Prague

Mgr. Miroslav Sedláček  
Head of Certification Body



Stamp



222274-01

**ELECTROINSTALLATION PLASTIC BOXES IN ENCLOSED DESIGN AND ACCESSORIES****Electroinstallation plastic boxes in enclosed design 8130, 8135, 003...,005... (-5°C do +60°C)**

Type	Material	Ratings	
8130	body PE, cover PP	400V	IP 54
8135	body PE, cover PP	400V	IP 54

**Accessories**

Sealings	1630-1635
Cable glands	G-49, 1601, 1611, 1618
Screwless terminals	TYP 015-TYP 018
Multipolar terminals	TYP 210-TYP 612
Terminals	S-66, S-96, SP-96

Type	Ratings	
005.PL.K	400V, 16 A	IP 65
003.CS.K	400V, 16 A	IP 65
003.CS.VO.K	400V, 16 A	IP 65
005.CS.K	400V, 16 A	IP 65
005.CS.VO.K	400V, 16 A	IP 65
005.CV.K	400V, 16 A	IP 65
005.CV.VO.K	400V, 16 A	IP 65

