

EU DECLARATION OF CONFORMITY

No. 1A-EU-10/23-04

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**
Havlíčková 432
280 02 Kolín
Czech Republic
IČ: 61672971
DIČ: CZ61672971

declare under our sole responsibility that

the product: **Electroinstallation plastic boxes in enclosed design with accessories**
Type: **8130, 8135, 003.., 005..**

manufacturer: **KOPOS KOLÍN a.s. Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: Boxes and covers for electric accessories for house and other similar fixed electrical installations.
Temperature resistance of the boxes is -5 ° C to + 60 ° C (except for the box 003.. and 005.. -25°C to +60°C).
Glow-wire test: 850°C except for the box 003.. and 005.. -25°C to +60°C).

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN IEC 60670-1 ed. 2:21 05 including amendments ČSN EN 60670-1:05+Z1:10+A1:13+Z2:21 05 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 05 including amendments (EN 60670-22:07 including amendments)	Test Report No. 222274-01/01 of 28.03.2023 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	Note: boxes 003.. and 005.. according to the note in article 12.3 of the ČSN EN IEC 60670-1 ed.2:21 standard, the air distance from the wall does not comply
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments)	Test Report No. 604792-01/01 of 25.11.2016 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	X
2014/35/EU - LVD	Zákon č. 90/2016 Sb. v platném znění NV 118/2016 Sb. v platném znění	ČSN EN 62262:97 včetně změn	Test Report No. 501073-01/01 of 31.3.2015 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	IK 06 8130 8135

Regulation 1907/2006 - REACH				Safety data sheets for used materials
------------------------------------	--	--	--	--

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.

Conformity assessment module: **MODUL A: Internal production control**

Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalogy>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and 50001:2018 according to the National program „Safety Enterprise“.


Signed on behalf of KOPOS KOLÍN a.s.

Place of issue: Kolín, Czech Republic

Date of issue: 20.04.2023



Ing. Jana Dejmková
quality director

KOPOS KOLÍN a.s. 
Havlíčková 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz

Enclosure No. 1 to EU Conformity Declaration No. 1A-EU-10/23-04

ELECTROINSTALLATION PLASTIC BOXES IN ENCLOSED DESIGN AND ACCESSORIES

Elektroinstalační krabice plastové v uzavřeném provedení 8130, 8135, 003...,005... (-5°C do +60°C)



Electroinstallation plastic boxes in enclosed design 8130, 8135, 003...,005... (-5°C do +60°C)

Typ/Type	Materiál/ Material	Jmenovité Hodnoty/ Ratings	
8130	body PE, cover PP	400V	IP 54
8135	body PE, cover PP	400V	IP 54

Příslušenství/Accessories

Ucpávky/Sealings	1630-1635
Průchodky/ Cable glands	G-49, 1601, 1611, 1618
Bezšroubové svorky/ Screwless terminals	TYP 015-018
Vícepólové svorkovnice/ Multipolar terminals	TYP 210-612
Svorkovnice/ Terminals	S-66, S-96, SP-96

Typ/ Type	Jmenovité hodnoty/ Ratings	
005.PL.K	400V, 16 A	IP 65
003.CS.K	400V, 16 A	IP 65
003.CS.VO.K	400V, 16 A	IP 65
005.CS.K	400V, 16 A	IP 65
005.CS.VO.K	400V, 16 A	IP 65
005.CV.K	400V, 16 A	IP 65
005.CV.VO.K	400V, 16 A	IP 65


KOPOS KOLÍN a.s. 
Havlíčkova 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz

