

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 2230014

Ordering firm: KOPOS KOLÍN a.s.
Havlíčkova 432, 280 02 Kolín IV, Czech Republic

Manufacturer/Licence holder: KOPOS KOLÍN a.s.
Havlíčkova 432, 280 02 Kolín IV, Czech Republic

Name of product: Electroinstallation box KSK

Trade name:

Type of product: KSK 80, KSK 100, KSK 125, KSK 175
Variants: grey, black
Hard material: PPC or PP, soft material: TPE, lid: PA

Rating: U_i 1000 V, IP66, -25 °C to +60 °C

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „ESČ Mark“ certification scheme is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESC Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 230639-01/01 of: 26.04.2023, 222523-01/01 of: 25.11.2022

A sample of the product was tested and found to be in conformity with:
ČSN EN IEC 60670-1 ed. 2:21+A11:21, ČSN EN 60670-1:05+Z1:10+A1:13+Z2:21,
ČSN EN 60670-22:07, ČSN EN 60695-11-5 ed. 2:17

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 No. 230296-01 of: 18.04.2023
- the Agreement on the use of the ESC Mark No. 230639 concluded between the ordering firm and the Electrotechnical Testing Institute

Other data:

05.05.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



* C E R / 2 2 3 0 0 1 4 *

230639-01